

**Part III Form 2
Section 11. ANNUAL REPORT.**

Drinking-Water System Number:	210000906
Drinking-Water System Name:	Lambton Area Water Supply System
Drinking-Water System Owner:	Lambton Area Water Supply System
Drinking-Water System Category:	Large Municipal Residential System
Period being reported:	Jan 1, 2005 to December 31, 2005

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking-Water System serve more than 10,000 people? Yes No

Is your annual report available to the public at no charge on a web site on the Internet? Yes No

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

www.rivernet.net/~lawss/

Lambton Area Water Supply System
1215 Fort St. Sarnia, ON. P.O. Box 790

City of Sarnia Municipal Office
255 N Christina St. Sarnia, ON

Village of Pt. Edward Municipal Office
135 Kendall St. Pt. Edward

St. Clair Township Municipal Office
1155 Emily St.
Mooretown, ON

Town of Plympton-Wyoming Municipal Office
546 Niagara St.
Wyoming ON

Township of Warwick Municipal Office
6332 Nauvoo Rd.
RR#8 Watford

Lambton Shores Municipal Office
19 Ann St.
Forest ON

The Township of Brooke-Alvinston
Municipal Office
3236 River St.
P.O. Box 28
Alvinston Ontario

Complete for all other Categories.

Number of Designated Facilities served:

N/A

Did you provide a copy of your annual report to all Designated Facilities you serve?

Yes No N/A

Number of Interested Authorities you report to:

N/A

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?

Yes No N/A

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
City of Sarnia Distribution System (receives SOME of their drinking water from Enniskillen System)	260003136
Village of Pt. Edward Distribution System	210000924
St. Clair Township Distribution System,	260006464
The Township of Plympton –Wyoming Distribution System	260006594
Warwick-Watford Distribution System	260001799
Township of Brooke-Alvinston Distribution System (receives SOME of their drinking water from Enniskillen System)	260040170
Lambton Shores Distribution System (receives SOME of their drinking water from this system)	260006594

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes No

Indicate how you notified system users that your annual report is available, and is free of charge.

Public access/notice via the web

Public access/notice via Government Office

Public access/notice via a newspaper

Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method _____

Describe your Drinking-Water System
Water Treatment Plant:

The Lambton Area Water Supply System (LAWSS) is a direct filtration facility with a maximum rated capacity of 181,844m³. The Water Treatment Plant uses chemically assisted filtration with disinfection.

The facility consists of an intake system a low lift pumping system, a treatment system and distribution pumping system that supplies water to the above listed drinking water systems. Water is drawn into the plant (a zebra mussel chemical control system is available as needed) via a 1675mm intake pipe, located approx. 100 m into the St. Clair River at a depth of 15 m and screened at the surge wells (pre-disinfection is utilized). Water flows to the Low Lift pump wet wells where a total of 4 vertical turbine pumps are located and used as needed which pump to a common discharge header. Here, coagulant is added, flashed mixed (PAC is also applied at this location when needed for taste and odour) The raw water is then flocculated (Polymer is added at the flocculation trains when needed) and diverted to filtration (10 dual media filters). The gravity fed filter effluents combine into two clearwells where sodium hypochlorite is injected . To maximize the contact time, the treated water is diverted to the two baffled reservoirs (in series) and fluoridated upon exiting the reservoir(s). Six vertical turbine pumps are available for supplying the distribution demand as needed. The water treatment process and distribution components are controlled by a dedicated SCADA computer system and monitored by certified operators 24 hours a day. Should a power failure occur, generators are available to permit the treatment plant to remain in operation.

The utility serves a large part of Lambton County and has over 250 kilometres of pipeline of various sizes and materials. The LAWSS distribution system has three standpipes and one elevated tower. There is also the East Lambton Booster Station with 9,000 m³ of storage and a pumping station (West Lambton Pumping Station), with water storage of 90,000m³.

The pumping/booster station(s) are controlled and monitored from the Lambton WTP via SCADA.

Emergency Water Line connections exist between LAWSS and the following drinking water systems:

Chatham-Kent: A connection at Whitebread Line and Hwy #40

Petrolia: Confederation Line and Ploughing Match Rd.

Grand Bend: Lakeshore Rd. & NW corner of Ipperwash Rd.

In Progress: Residual Management System: The capital project is in progress. The system when completed will provide treatment to backwash water and allow this clarified water to be discharged to the St. Clair River. Projected time of commissioning is Feb./March 2006.

List all water treatment chemicals used over this reporting period

Sodium Hypochlorite – disinfection

Hydrofluosilicic Acid- fluoridation

Clar+Ion A7 (Aluminum Sulphate)- coagulation

Powder Activated Carbon- taste and odor (when required)

Polymer 8103 + filter aid (when required)

Note: all chemicals are NSF/ANSI approved

Were any significant expenses incurred to?

Install required equipment

Repair required equipment

Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

Residual Management System Project Continuation	\$1,000,000 (total project \$4.7 Million)
Campbell St. Watermain replacement (Milton- Savoy)	\$ 749,000
Filter rehabilitation (2 complete filter rebuilds)	\$155,000
SCADA upgrades	\$152,000
Watermain/Hydrant/Valve Box repair(s)	\$145,000
Replace High Lift pump # 3 motor and associated protective devices	\$57,000
“Strategies for Treating Turbidity Spikes” (Turbidity Report)	\$19,000
Watermain interconnection between LAWSS and Watford distribution system	\$30,000
Forest/Watford (E.L.B.S) Recirculation Valve Actuators (Rotork Valves)	\$17,000
Replace/install NaOCl Storage Tank(s)	\$17,000
Replace and install Backwash Rate Control Valve (Butterfly valve)	\$15,400
Meter calibration	\$8,600
Water Tower/Standpipe(s) Inspections and Reports	\$6,000
* all costs are approximate	

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
May 4/05 AWQI #54362	HPC	>1500	cfu/ml	Re-sample	May 5/05

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number Of Background Samples	Range of Background Results (#-#)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	53	0-10	0-340				
Treated	497	0-0 cfu/100ml	0-0 cfu/100ml	497	0-13 cfu/100ml	494	0 - >1500 cfu/ml
Distribution							

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	8760	0.020 - 0.695 NTU
Chlorine (free)	8760	0.92 - 1.92 mg/L
Fluoride (If the DWS provides fluoridation)	8760	0.37 - 0.94 mg/L

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is not milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure

Summary of Inorganic parameters tested during this reporting period or the most recent sample results
Note: ppb= parts per billion = micrograms per litre

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	*Jan –Dec./05	<0.6	ppb	No
Arsenic	*Jan –Dec./05	<2	ppb	No
Barium	*Jan –Dec./05	13 - 14	ppb	No
Boron	*Jan –Dec./05	10 - 15	ppb	No
Cadmium	*Jan –Dec./05	<0.1 – 0.1	ppb	No
Chromium	*Jan –Dec./05	<3	ppb	No
Lead	*Jan –Dec./05	<0.1 – 0.2	ppb	No
Mercury	*Jan –Dec./05	<0.02	ppb	No
Selenium	*Jan –Dec./05	<3	ppb	No
Sodium	2004/01/21	6.4	mg/L	No
Uranium	*Jan –Dec./05	0.12	ppb	No
Fluoride	<i>(continuous on-line monitoring)</i>	0.37-0.94	mg/L	No
Nitrite	*Jan –Dec./05	< 0.005 - 0.005	mg/L	No
Nitrate	*Jan –Dec./05	0.08 - 0.13	mg/L	No

***Note: Inorganic parameters are tested quarterly. If a parameter was/is detectable the range of detection has been provided and reported in the table above.**

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	*Jan –Dec./05	< 0.11	ppb	No
Aldicarb	*Jan –Dec./05	< 0.30	ppb	No
Aldrin + Dieldrin	*Jan –Dec./05	< 0.067	ppb	No
Atrazine + N-dealkylated metabolites	*Jan –Dec./05	< 0.12	ppb	No
Azinphos-methyl	*Jan –Dec./05	< 0.21	ppb	No
Bendiocarb	*Jan –Dec./05	< 0.13	ppb	No
Benzene	*Jan –Dec./05	< 0.36	ppb	No
Benzo(a)pyrene	*Jan –Dec./05	< 0.004	ppb	No
Bromoxynil	*Jan –Dec./05	< 0.09	ppb	No
Carbaryl	*Jan –Dec./05	< 0.16	ppb	No
Carbofuran	*Jan –Dec./05	< 0.37	ppb	No
Carbon Tetrachloride	*Jan –Dec./05	< 0.34	ppb	No

Chlordane (Total)	*Jan –Dec./05	< 0.11	ppb	No
Chlorpyrifos	*Jan –Dec./05	< 0.18	ppb	No
Cyanazine	*Jan –Dec./05	< 0.18	ppb	No
Diazinon	*Jan –Dec./05	< 0.081	ppb	No
Dicamba	*Jan –Dec./05	< 0.17	ppb	No
1,2-Dichlorobenzene	*Jan –Dec./05	< 0.56	ppb	No
1,4-Dichlorobenzene	*Jan –Dec./05	< 0.25	ppb	No
Dichlorodiphenyltrichloroethane (DDT) + metabolites	*Jan –Dec./05	< 0.14	ppb	No
1,2-Dichloroethane	*Jan –Dec./05	< 0.32	ppb	No
1,1-Dichloroethylene (vinylidene chloride)	*Jan –Dec./05	< 0.52	ppb	No
Dichloromethane	*Jan –Dec./05	< 1.17	ppb	No
2-4 Dichlorophenol	*Jan –Dec./05	< 0.15	ppb	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	*Jan –Dec./05	< 0.11	ppb	No
Diclofop-methyl	*Jan –Dec./05	< 0.13	ppb	No
Dimethoate	*Jan –Dec./05	< 0.12	ppb	No
Dinoseb	*Jan –Dec./05	< 0.084	ppb	No
Diquat	*Jan –Dec./05	< 1	ppb	No
Diuron	*Jan –Dec./05	< 0.871	ppb	No
Glyphosate	*Jan –Dec./05	< 6.01	ppb	No
Heptachlor + Heptachlor Epoxide	*Jan –Dec./05	< 0.11	ppb	No
Lindane (Total)	*Jan –Dec./05	< 0.056	ppb	No
Malathion	*Jan –Dec./05	< 0.91	ppb	No
Methoxychlor	*Jan –Dec./05	< 0.14	ppb	No
Metolachlor	*Jan –Dec./05	< 0.092	ppb	No
Metribuzin	*Jan –Dec./05	< 0.12	ppb	No
Monochlorobenzene	*Jan –Dec./05	< 0.46	ppb	No
Paraquat	*Jan –Dec./05	< 1	ppb	No
Parathion	*Jan –Dec./05	< 0.18	ppb	No
Pentachlorophenol	*Jan –Dec./05	< 0.15	ppb	No
Phorate	*Jan –Dec./05	< 0.11	ppb	No
Picloram	*Jan –Dec./05	< 0.2	ppb	No
Polychlorinated Biphenyls(PCB)	*Jan –Dec./05	< 0.04	ppb	No
Prometryne	*Jan –Dec./05	< 0.23	ppb	No
Simazine	*Jan –Dec./05	< 0.15	ppb	No
THM (NOTE: show latest annual average)	*Jan –Dec./05	40.06	ppb	No
Temephos	*Jan –Dec./05	< 0.31	ppb	No
Terbufos	*Jan –Dec./05	< 0.12	ppb	No
Tetrachloroethylene	*Jan –Dec./05	< 0.48	ppb	No
2,3,4,6-Tetrachlorophenol	*Jan –Dec./05	< 0.14	ppb	No
Triallate	*Jan –Dec./05	< 0.1	ppb	No
Trichloroethylene	*Jan –Dec./05	< 0.54	ppb	No

2,4,6-Trichlorophenol	*Jan –Dec./05	< 0.25	ppb	No
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)	*Jan –Dec./05	< 0.14	ppb	No
Trifluralin	*Jan –Dec./05	< 0.12	ppb	No
Vinyl Chloride	*Jan –Dec./05	< 0.08	ppb	No

***Note: Organic parameters are tested quarterly. Average values are reported in the table above.**

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample

(Only if DWS category is large municipal residential, small municipal residential, large municipal non residential, non municipal year round residential, large non municipal non residential)