



Ontario Clean Water Agency
Agence Ontarienne Des Eaux



Annual Summary Report

Lambton Area Water Supply System

2019

Prepared for the Lambton Area Water Supply System Board

By the Ontario Clean Water Agency

TABLE OF CONTENTS

| Section Number | CONTENTS | Page Number |
|-----------------------|---|--------------------|
| 1 | <p>"Compliance with the Safe Drinking Water Act and Regulation 170/03, the system's approval, drinking water works permit, municipal drinking water licence and any orders applicable to the system "</p> <p><i>Statement of Compliance</i></p> | 2 |
| 2 | <p>"Non-Compliance with the Safe Drinking Water Act and Regulation 170/03, the system's approval, drinking water works permit, municipal drinking water licence and any orders applicable to the system"</p> <p><i>Details of the non-compliance issues as well as how and when any non-compliance issues were corrected</i></p> | 2 |
| 3 | <p>"Assessment of the capability of the system to meet existing and planned uses of the system"</p> <p><i>Summary and discussion of quantity of water supplied</i></p> | 3 |
| APPENDIX | | |
| Appendix A | Annual volume record of the Lambton Area Water Supply System January 1, 2019 – December 31, 2019 | 4-5 |

Lambton Area Water Supply System Annual Summary Report 2019

SECTION 1

Statement of Compliance

This report is a summary of water quality information for the Lambton Area Water Supply System and published in accordance with Schedule 22 of Ontario's Safe Drinking Water Act, Ontario Regulation 170/03 for the reporting period of January 1, 2019 to December 31, 2019. The Lambton Area Water Supply System is categorized as a Large Municipal Residential Drinking Water System.

This report was prepared by the Ontario Clean Water Agency on behalf of the Lambton Area Water Supply System Board.

The Lambton Area Water Supply System was operated and maintained in such a manner that the water supplied to the consumers serviced by the system satisfied all the requirements in the Safe Drinking Water Act, the Certificate of Approval and the Municipal Drinking Water Licence. There were no adverse water quality events/non-compliance issues reported.

SECTION 2

Details of the non-compliance issues as well as how and when any non-compliance issues were corrected

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Notice of Resolution |
|----------------------|-------------------|---------------|------------------------|--------------------------|-----------------------------|
| | Zero noted | | | | |

SECTION 3

Summary and discussion of quantity of water supplied

In accordance with Schedule 22-2 (3) *“the report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system.”*

- 1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows and daily instantaneous peak flow rate.*
- 2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system’s approval must be discussed.*

The rated capacity specified in the Municipal Drinking Water Licence (Licence Number: 020-101) for the Lambton Area Water Supply System is 181,844 m³/day. The maximum treated daily flow for the reporting period was 97,988 m³/day on June 27, 2019. The rated capacity from the Municipal Drinking Water Licence was not exceeded.

The Permit to Take Water (Number 3657-7DJL86) states the maximum amount of water taken is 182,000,000 L/Day. The maximum amount of raw water taken in 2019 was 100,783,000 L on June 27, 2019. The Permit to Take Water limit was not exceeded.

Attached in Appendix A, are the average daily volume (m³), the maximum daily volume (m³) and the peak daily flow rate (L/sec) for treated water and raw. Also noted is the % of Design Volume for each.

The quantity of water supplied during the reporting period did not exceed the rated capacity of this facility.

Lambton Area Water Supply System Annual Summary Report 2019

Appendix A

Lambton Area Water Supply System Annual Volume Record for 2019

Design Rated Capacity (Treated Flows): 181,844 m³/day

| Month | Average Daily Volume of Treated Water (m ³) | % of Design Volume | Maximum Daily Volume (m ³) | % of Design Volume | Peak Daily Rate (L/sec) | % of Design Rate of 2104 L/sec |
|-----------|---|--------------------|--|--------------------|-------------------------|--------------------------------|
| January | 44841 | 24.7 | 51137 | 28.1 | 789 | 37.5 |
| February | 46364 | 25.5 | 53292 | 29.3 | 793 | 37.7 |
| March | 46748 | 25.7 | 51967 | 28.6 | 916 | 43.5 |
| April | 44048 | 24.2 | 49343 | 27.1 | 795 | 37.8 |
| May | 48461 | 26.6 | 52401 | 28.8 | 968 | 46.0 |
| June | 61126 | 33.6 | 97988 | 53.9 | 1363 | 64.8 |
| July | 76220 | 41.9 | 96442 | 53.0 | 1340 | 63.7 |
| August | 67155 | 36.9 | 77634 | 42.7 | 1081 | 51.4 |
| September | 56044 | 30.8 | 64029 | 35.2 | 1029 | 48.9 |
| October | 47286 | 26.0 | 60875 | 33.5 | 863 | 41.0 |
| November | 45425 | 25.0 | 50600 | 27.8 | 861 | 40.9 |
| December | 45201 | 24.9 | 51407 | 28.3 | 830 | 39.4 |

Lambton Area Water Supply System Annual Summary Report 2019

Permit to Take Water Max Flow (Raw Water): 182,000 m³/day

| Month | Average Daily Volume of Raw Water (m³) | % of Permit Volume | Maximum Daily Volume (m³) | % of Permit Volume | Peak Daily Rate (L/sec) | % of Permit Rate of 2106 L/sec |
|--------------|--|---------------------------|---|---------------------------|--------------------------------|---------------------------------------|
| January | 45509 | 25.0 | 52987 | 29.1 | 613 | 29.1 |
| February | 48756 | 26.8 | 56479 | 31.0 | 654 | 31.1 |
| March | 48622 | 26.7 | 56245 | 30.9 | 651 | 30.9 |
| April | 45139 | 24.8 | 51694 | 28.4 | 598 | 28.4 |
| May | 49349 | 27.1 | 56670 | 31.1 | 655 | 31.1 |
| June | 62009 | 34.1 | 100783 | 55.4 | 1166 | 55.4 |
| July | 76681 | 42.1 | 98594 | 54.2 | 1141 | 54.2 |
| August | 66885 | 36.7 | 80666 | 44.3 | 934 | 44.3 |
| September | 55970 | 30.8 | 61463 | 33.8 | 927 | 44.0 |
| October | 47563 | 26.1 | 59068 | 32.5 | 684 | 32.5 |
| November | 46161 | 25.3 | 55288 | 30.3 | 640 | 30.4 |
| December | 46399 | 25.5 | 52646 | 28.9 | 609 | 28.9 |